



UROX.S3417 Smoke-automatic Fire Detectors

[Page Bottom](#)

Smoke-automatic Fire Detectors

[See General Information for Smoke-automatic Fire Detectors](#)**FIRE FIGHTING ENTERPRISES LTD**

S3417

9 HUNTING GATE

WILBURY WAY

HITCHIN, HERTFORDSHIRE SG4 OTJ UNITED KINGDOM

Detector		Compatibility		Velocity Range (fpm)	
Model	Application	Type	Restrictions	Min	Max
Fireray 2000 (a), Fireray 2000 ETS (a), Fireray 3000 (a), Fireray 5000, 50RU, 100RU, EC-50R, EC-100R					
	OAP	PB	None		

OAP - Open Area Protection

PB - Projected Beam

(a) - Suitable for use in ambient temperatures of -20 to 55 C (-4 to 131 F).

[Last Updated](#) on 2012-02-28[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".